


OSNA NAMUR Proximity Switches have been approved by BUREAU VERITAS as per Certificate No. EPS 16 ATEX 1 047  II 2G Ex ia IIC T4 Gb for Intrinsic Safety.


These Switches can be installed in a Hazardous Area Gas Group IIC and connected through a Isolation Trip Amplifier.

For Example : OSNA OS-Ex-2G also certified as Intrinsic Safe by BUREAU VERITAS.

## CONNECTION DIAGRAMS



PVC Cable  
IP-67 Protection



Supply Voltage

8 VDC

Mounting

Non Flush

Current Consumption

(A) Active Face Free

$\geq 3\text{mA}$

(B) Active Face Covered

$\leq 1\text{mA}$

Intrinsic Capacitance

145nF

Intrinsic Inductance

108mH

Switching Frequency

100Hz

Switching Hysteresis

3%

Standard Target(Ferrous)

45x45x1

Cable (Cross Section)

0.75mm<sup>2</sup>

## Ordering Chart

METAL HOUSING

NJ 15-30-GM-N

ART. NO. : (SIN018M2)

SYNTHETIC HOUSING